



AVERAGE LOSS OF WATER LEAKING FAUCETS OVER A PERIOD OF ONE MONTH




30
DROPS
PER
MINUTE

54
GALLONS
PER
MONTH




60
DROPS
PER
MINUTE

113
GALLONS
PER
MONTH




120
DROPS
PER
MINUTE

237
GALLONS
PER
MONTH



1/2"

1014
GALLONS
PER
MONTH



1 1/2"

2202
GALS.
PER
MONTH

SMALL, CONTINUOUS LEAKS WILL WASTE LARGE AMOUNTS OF WATER. IN ADDITION,
LEAKS IN HOT-WATER LINES WILL WASTE HEAT. KEEP ALL VALVES AND FAUCETS TIGHT.
WHEN A LEAK DEVELOPS, REPLACE FAUCET WASHERS, IF VALVES OR FAUCETS ARE
DAMAGED, REPLACE FAUCET OR VALVE ASSEMBLY.